

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATENo. 340Dated: 24/04/2024

It is certified that an inspection team headed by Er. Faizan Atique (Junior Engineer) and Sri Dharmendra Kumar (Lab Asst.) from Public Health Sub-Division, Laheriasarai Darbhanga. inspected G.D. Goenka Public School, Poria, Hanumannagar Darbhanga on 24/04/2024 and found that the G.D. Goenka Public School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 01 (one) year

Signature with Seal:

Sudh
24/04/24

Sub-Divisional Officer

Name : Er. Sudhanshu Shekhar Choudhary (Janga)

Designation: Assistant Engineer

Name & Address of the Office / Department

P H Sub-Division Laheriasarai

To,

Principal

G.D. Goenka Public School,Poria, Hanumannagar Darbhanga.

Vinay Kumar
Manager
GD Goenka Public School
Darbhanga

Anita Paulson
Principal
GD Goenka Public School
Darbhanga

District Level water Testing Laboratory Darbhanga DLWTL

Government of Bihar

Public Health Engineering Department

District Name: Darbhanga

Sample collected by : Donanath Prasad

Sl. No.	Block	Panchayat	Village	Location of Source	Parameters														Total Coli	Remarks	
					pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka	Fe	NO ₃	SO ₄	F	As			
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	
1	Hanuman Nagar	Godhalla	pora	GD Goanka Public School	7.84	NT	230	150	90	24	15.84	48	146	0.14	8	NT	0.8	0.001	(-y)		
						6.5	5.0	500	200	75	30	250	200	0.3	45	25	1.0	0.01			
						8.5	10.0	2000	600	200	100	1000	600	1.0	NR	400	1.5	NR			

Vinay Kumar
Manager
GD Goenka Public School
Darbhanga

Principal
GD Goenka Public School
Darbhanga

Armedra Kumar
Chemist 24/11/24
P.H Division Darbhanga